

# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	La Jolla High School	Date:	03/12/18	
Sampler:	SDUSD - Safety Office	Analyzed By:	EnviroMatrix Analytical, Inc	
<p><b>Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB.</b>                  Green shading = below District &amp; Federal Action Levels                  Yellow shading = below Federal Action level/Above District Action Level                  Red Shading = above Federal Action Level</p>				
Sample ID	Sample Location	Lead Results 03/12/18	Units	Type of Fixture
1	ADMIN NE STAFF LOUNGE S WALL	1.90	ug/L	CF
2	ADMIN NE HALL WAY, W WALL FACING RESTROOM, R Bubbler	2.70	ug/L	DB
3	ADMIN NE HALL WAY, W WALL FACING RESTROOM, L Bubbler	2.50	ug/L	DB
4	ADMIN - NE NURSE OFFICE, E WALL	5.00	ug/L	CF
5	ADMIN Ext Near ASB, E-Wall, L-Bubbler	4.30	ug/L	DB
6	ADMIN Ext Near ASB, E-Wall, R-Bubbler	2.10	ug/L	DB
7	LIBRARY S OFFICE, NW WALL	2.60	ug/L	CF
8	LIBRARY S HALLWAY, SE WALL NEAR RESTROOM	1.10	ug/L	DB
9	LIBRARY N OFFICE, NW WALL	2.80	ug/L	CF
<b>10</b>	<b>LIBRARY E EXTERIOR, R Bubbler (Previously Sampled)</b>			
11	LIBRARY E EXTERIOR, L Bubbler	1.70	ug/L	DB
12	LIBRARY W EXTERIOR	5.50	ug/L	DB
13	300 RM 301 E WALL	2.70	ug/L	CF
14	300 EXTERIOR OF RM 301, E-Wall	5.00	ug/L	DB
15	300 EXTERIOR OF RM 301, S-Wall, R-Side	1.90	ug/L	DB
16	300 EXTERIOR OF RM 301, S-Wall, L-Side ( <b>Very Low Flow</b> )	1.40	ug/L	DB
17	300 RM 305 E WALL	6.70	ug/L	CF
18	300 RM 306 E WALL	4.40	ug/L	CF
19	300 RM 304 E WALL	5.50	ug/L	CF
20	300 RM 312 N WALL	7.00	ug/L	CF
<b>21</b>	<b>300 W EXTERIOR OF RM 312, R Bubbler (Previously Sampled)</b>			
22	300 W EXTERIOR OF RM 312, L Bubbler	0.63	ug/L	DB
23	GIRLS' PE LOCKERS N EXTERIOR, Single Bubbler	1.70	ug/L	DB
24	SMALL GYM TRAINING RM S WALL	3.80	ug/L	CF
25	SMALL GYM E WALL	4.70	ug/L	DB

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	La Jolla High School	Date:	03/12/18
Sampler:	SDUSD - Safety Office	Analyzed By:	EnviroMatrix Analytical, Inc

**Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB.**  
 Green shading = below District & Federal Action Levels  
 Yellow shading = below Federal Action level/Above District Action Level  
 Red Shading = above Federal Action Level

Sample ID	Sample Location	Lead Results 03/12/18	Units	Type of Fixture
26	SMALL GYM W WALL	2.00	ug/L	DB
<b>27</b>	<b>SMALL GYM W WALL Cuspidor (DON'T SAMPLE)</b>			
28	BIG GYM E WALL	5.90	ug/L	DB
<b>29</b>	<b>BIG GYM E WALL Cuspidor (DON'T SAMPLE)</b>			
30	BIG GYM W WALL	1.70	ug/L	DB
<b>31</b>	<b>BIG GYM W WALL Cuspidor (DON'T SAMPLE)</b>			
32	BIG GYM WEIGHT RM (Wrestling Rm) W WALL	4.10	ug/L	DB
<b>33</b>	<b>BIG GYM WEIGHT RM W WALL Cuspidor (DON'T SAMPLE)</b>			
34	BIG GYM MEZZANINE E WALL	5.50	ug/L	DB
<b>35</b>	<b>BIG GYM MEZZANINE E WALL Cuspidor (DON'T SAMPLE)</b>			
36	BIG GYM N EXTERIOR, R Bubbler	2.50	ug/L	DB
37	BIG GYM N EXTERIOR, L Bubbler	1.60	ug/L	DB
38	1300 W EXTERIOR FACING TENNIS CRT, R Bubbler	0.13	ug/L	DB
39	1300 W EXTERIOR FACING TENNIS CRT, L Bubbler	0.079	ug/L	DB
40	1300 S-Ext, Between Bleachers & Spin Rm, Lower-Bubbler	0.22	ug/L	DB
41	1300 S-Ext, Between Bleachers & Spin Rm, Upper-Bubbler	0.17	ug/L	DB
42	1200 S EXTERIOR, R Bubbler	0.21	ug/L	DB
42	1200 S EXTERIOR, L Bubbler	0.14	ug/L	DB
44	1100 NE EXTERIOR, R Bubbler	0.26	ug/L	DB
45	1100 NE EXTERIOR, L Bubbler	0.23	ug/L	DB
46	Auditorium, Back Stage-Back N/E Entrance-Interior N/E Wall	1.60	ug/L	DB
47	Auditorium-Main Entrance-Interior Wall/Lobby-R Bubbler	1.70	ug/L	DB
48	Auditorium-Main Entrance-Interior Wall/Lobby- L Bubbler	4.30	ug/L	DB
49	Auditorium - Consession Rm/Box Office - Gooseneck	12.00	ug/L	CF

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	La Jolla High School	Date:	03/12/18	
Sampler:	SDUSD - Safety Office	Analyzed By:	EnviroMatrix Analytical, Inc	
<p><b>Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB.</b>                  Green shading = below District &amp; Federal Action Levels                  Yellow shading = below Federal Action level/Above District Action Level                  Red Shading = above Federal Action Level</p>				
Sample ID	Sample Location	Lead Results 03/12/18	Units	Type of Fixture
50	500 LOWER-N HALLWAY R Bubbler	3.30	ug/L	DB
51	500 LOWER-N HALLWAY L Bubbler	1.40	ug/L	DB
52	500 LOWER-S HALLWAY R Bubbler	3.70	ug/L	DB
53	500 LOWER-S HALLWAY L Bubbler	3.90	ug/L	DB
54	500 UPPER-N HALLWAY R Bubbler	2.30	ug/L	DB
55	500 UPPER-N HALLWAY L Bubbler	3.30	ug/L	DB
56	500 UPPER-S HALLWAY R Bubbler	8.30	ug/L	DB
57	500 UPPER-S HALLWAY L Bubbler	8.20	ug/L	DB
58	500 CAFETERIA DINING-S WALL R Bubbler	15.00	ug/L	DB
59	500 CAFETERIA DINING-S WALL L Bubbler	8.60	ug/L	DB
60	500 FACULTY DINING-S WALL	12.00	ug/L	CF
61	500 NW EXT NEAR J-5B JANITOR RM R Bubbler (Very Low Flow)	11.00	ug/L	DB
62	500 NW EXT NEAR J-5B JANITOR RM L Bubbler (Previously Sampled)			
63	500 W EXTERIOR R Bubbler (TURNED OFF)			
64	500 W EXTERIOR R Bubbler (TURNED OFF)			
65	500 KITCHEN S-WALL	1.80	ug/L	CF
66	500 KITCHEN N-WALL, Left Sink (Previously Sampled)			
67	500 KITCHEN N WALL R Sink	8.10	ug/L	CF
68	Rm. 602 wood shop single fountain NW wall	5.70	ug/L	DB
69	Rm. 603 Auto shop single fountain on S-wall	3.40	ug/L	DB
70	Rm.604 ceramics single fountain on SE wall	6.40	ug/L	DB
71	LAV bldg.-Outside SE-side near rm 901, L-Bubbler (Previously Sampled)			
72	LAV bldg.Outside SE-side near rm 901, R-Bubbler	0.59	ug/L	DB
73	LAV bldg.Outside NE-side, Near Girls RR, L-Bubbler	1.30	ug/L	DB
74	LAV bldg.Outside NE-side, Near Girls RR, R-Bubbler	0.70	ug/L	DB

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet




# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING


Coding: DB=Drinking Water bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING



Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet