

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	Angier Elementary School	Date:	02/05/18	
Sampler:	SDUSD - Safety Office	Analyzed By:	EnviroMatrix Analytical, Inc	
<p>Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB. Green shading = below District & Federal Action Levels Yellow shading = below Federal Action level/Above District Action Level Red Shading = above Federal Action Level</p>				
Sample ID	Sample Location	Lead Results	Units	Type of Fixture
1	Health Office South wall at sink	1.12	ug/L	DB
2	Student Center East wall at sink	4.65	ug/L	DB
3	Inside Cafeterial NE-Wall 1 at wall at hand washing trough sink	2.45	ug/L	DB
4	Inside Kitchen, E-Wall at two compartment sink	1.78	ug/L	DB
5	Inside Kitchen, S-Wall at sink (City Previously Sampled)			
6	Inside PTO South wall at sink (Rm is next to Cafeteria)	3.9	ug/L	DB
7	BLDG RMS 3-8 EXTERIOR Left Trough - RIGHT		ug/L	DB
8	BLDG RMS 3-8 EXTERIOR Left Trough - LEFT		ug/L	DB
9	BLDG RMS 3-8 EXT, Right Trough - Left Bubbler		ug/L	DB
10	BLDG RMS 3-8 EXT, R-Trough, R-Bubbler (City Previously Sampled)			
11	K-1, S-WALL R	2.11	ug/L	DB
12	K-1, W-WALL	6.07	ug/L	DB
13	K-2, N-Wall, bubbler on R-Side (City Previously Sampled)			
14	KINDER PLAYGROUND W-WALL R-Side	2.31	ug/L	DB
15	RM 3, S-WALL R-side	3.51	ug/L	DB
16	RM 4, S-WALL, R-Side	3.73	ug/L	CF
17	RM 5, S-WALL, R-Side	0.96	ug/L	DB
18	RM 6, W-WALL, R-Side	10.8	ug/L	DB
19	RM 7, W-WALL, R-Side		ug/L	DB
20	RM 8, W-WALL, R-Side	2.95	ug/L	DB
21	Ext, near Rm 9, L-Trough, L-Side (City Previously Sampled)			
22	Ext, near Rm 9, L-Trough, R-Side			DB
23	Ext, near Rm 9, R-Trough, L-Side	0.85	ug/L	DB
24	Ext, near Rm 9, R-Trough, R-Side	0.63	ug/L	DB
25	Ext, near Rm 9, single bubbler	0.82	ug/L	DB

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	Angier Elementary School	Date:	02/05/18	
Sampler:	SDUSD - Safety Office	Analyzed By:	EnviroMatrix Analytical, Inc	
Sample ID	Sample Location	Lead Results	Units	Type of Fixture
<div style="border: 1px solid black; padding: 5px;"> <p>Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB. Green shading = below District & Federal Action Levels Yellow shading = below Federal Action level/Above District Action Level Red Shading = above Federal Action Level</p> </div>				
26	Rm 9, NW Wall, gooseneck (Special Ed Classroom)	3.02		DB
27	Rm 9, NW Wall, Bubbler (Special Ed Classroom)	1.58	ug/L	DB
28	Rm 10, NW Wall, gooseneck (Special Ed Classroom)	5.69	ug/L	DB
29	Rm 10, NW Wall, Bubbler (Special Ed Classroom)	2.12	ug/L	DB
30	Rm 11, NW Wall	9.99	ug/L	DB
31	Rm 12, SE Wall, gooseneck (Staff Lounge)	2.73	ug/L	DB
32	Rm 12, SE Wall, Bubbler (Staff Lounge)	1.16	ug/L	DB
33	Rm 13, SE Wall	1.94	ug/L	DB
34	Rm 14, SE Wall	3.43	ug/L	DB
35	Rm 15, SE Wall	5.64	ug/L	DB
36	Ext Bubbler, Rm 16, West Wall, Far Left (Left set of 3)	1.27	ug/L	DB
37	Ext Bubbler, Rm 16, West Wall, Middle (Left set of 3)	0.98	ug/L	DB
38	Ext Bubbler, Rm 16, West Wall, Far Right (Left set of 3)	1.08		DB
39	Ext Bubbler, Rm 16, West Wall, Far Left (Right set of 3)	1.24	ug/L	DB
40	Ext Bubbler, Rm 16, West Wall, Middle (Right set of 3)	1.44	ug/L	DB
41	Ext Bubbler, Near Rm 16, West Wall, Far Right (Right set of 3) (City Previously Sampled)			
42	Rm 16, West Wall, Bubbler	2.13	ug/L	CF
43	Rm 17, West Wall, Bubbler	2.70	ug/L	DB
44	Rm 18, West Wall, Bubbler	12.2	ug/L	DB
45	Rm 19, East Wall, Bubbler	3.49	ug/L	DB
46	Rm 20, East Wall, Bubbler	2.51	ug/L	DB
47	Rm 21, East Wall, Bubbler	2.66	ug/L	DB
48	Rm 22, East Wall, Bubbler	2.38	ug/L	DB
49	Rm B23, West Wall, Bubbler	2.33	ug/L	DB

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	Angier Elementary School	Date:	02/05/18	
Sampler:	SDUSD - Safety Office	Analyzed By:	EnviroMatrix Analytical, Inc	
Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB. Green shading = below District & Federal Action Levels Yellow shading = below Federal Action level/Above District Action Level Red Shading = above Federal Action Level				
Sample ID	Sample Location	Lead Results	Units	Type of Fixture
50	Rm B24, West Wall, Bubbler	2.01	ug/L	DB
51	Bungalow B-2/ East Wall-Unoccupied	1.59	ug/L	DB
52	Bungalow B-3/ East Wall-Unoccupied	0.46	ug/L	DB
53	Bungalow B-4/ East Wall	0.48	ug/L	DB
54	Bungalow B-5/ East Wall	0.66	ug/L	DB
2017 City Water Department Sampling Results				
W1168186	Lunch Court area near Rm 9. Far left bubbler of exterior fountains closest to girls RR	<5	ug/L	DB
W1168187	Exterior next to Room 16. Two triple fountains, right bubbler on right fountain	<5	ug/L	DB
W1168188	Cafeteria/Kitchen. South interior wall in the corner in kitchen; spray faucet	10.2	ug/L	DB
W1168189	West exterior wall next to custodial room; two double fountains, right bubbler of right fountain	<5	ug/L	DB
W1168190	Kindergarten; inside k-2; bubbler on the right side of sink	<5	ug/L	DB

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet