

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	Gage Elementary School	Report Date:	02/17/18	
Sampler:	SDUSD - Safety Office	Analyzed By:	EnviroMatrix Analytical, Inc	
Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB. Green shading = below District & Federal Action Levels Yellow shading = below Federal Action level/Above District Action Level Red Shading = above Federal Action Level				
Sample ID	Sample Location	Lead Results	Units	Type of Fixture
1	Admin Building, Nurse's office, N-Wall	2.72	ug/L	NS
2	Admin Building, Work Room, E-Wall	4.23	ug/L	KF
3	Room 19, N-Wall	2.63	ug/L	DB
4	Lunch Court Single Bubbler (previously sampled)			
5	Kitchen, E-Wall	1.47	ug/L	KF
6	K-1, North facing Triple facuet, bubbler right side	3.58	ug/L	DB
7	K-1, North Wall (previously sampled)			
8	Ext Bubbler between K-1 &K-2 SE facing wall (very low flow)	4.49	ug/L	DB
9	Ext. K-3 L- Side (previously sampled)			
10	Ext. K-3, Center, (Secured-Do Not Sample)			
11	Ext. K-3, R- Side (Secured - Do not Sample)			
12	K-3, North wall, left goose neck facuet	7.27	ug/L	CF
13	K-3, North wall, right Bubbler	4.71	ug/L	DB
14	K-4, Northeast wall, Bubbler	1.25	ug/L	DB
15	Room 1 - NE wall at sink	5.86	ug/L	DB
16	Room 2 - SE wall at sink	4.72	ug/L	DB
17	Room 3 - NE wall at sink	6.71	ug/L	DB
18	Room 4 - SE wall at sink	3.97	ug/L	DB
19	Room 5 - NE wall at sink	4.01	ug/L	DB
20	Room 6 - SE wall at sink	4.78	ug/L	DB
21	Ext.(Rm's 1-6) E-Wall R-Side Single Bubbler (previously sampled)			
22	Ext. (Rm's 1-6) E- Wall, Double Basin, L-side	1.61	ug/L	DB
23	Ext. (Rm's 1-6) E- Wall, Double Basin, R-side	3.57	ug/L	DB
24	Ext. (Rm's 7-12) E-Wall, Triple Basin, L-Side	1.03	ug/L	DB
25	Ext. (Rm's 7-12) E-wall, Triple Basin, Center	0.70	ug/L	DB
26	Ext. (Rm's 7-12) E-Wall, Triple Basin, R-Side	0.96	ug/L	DB

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	Gage Elementary School	Report Date:	02/17/18	
Sampler:	SDUSD - Safety Office	Analyzed By:	EnviroMatrix Analytical, Inc	
<p>Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB.</p> <p>Green shading = below District & Federal Action Levels</p> <p>Yellow shading = below Federal Action level/Above District Action Level</p> <p>Red Shading = above Federal Action Level</p>				
Sample ID	Sample Location	Lead Results	Units	Type of Fixture
27	Rm. 7- SE wall at sink- Left side of sink-gooseneck	4.64	ug/L	CF
28	Room 7 - SE wall at sink - Right side of sink	1.91	ug/L	DB
29	Room 8 - SE wall at sink	8.82	ug/L	DB
30	Room 9 - SE wall at sink	2.02	ug/L	DB
31	Room 10 - NW wall at sink	5.73	ug/L	DB
32	Room 11 - NW wall at sink	3.75	ug/L	DB
33	Room 12 - NW wall at sink	3.62	ug/L	DB
34	Rm 13 SE Wall (water off)			
35	Room 14 SE Wall (water off)			
36	Room 15 SE Wall	4.93	ug/L	DB
37	Ext Bldg Rooms 13 - 18, SW wall, R-Bubbler (low flo)	0.96	ug/L	DB
38	Ext Bldg Rooms 13 - 18, SW Wall, C - Bubbler (very low-zero flo)	0.80	ug/L	DB
39	Bldg Rooms 13 - 18 Exterior SW Wall Left Bubbler	0.80	ug/L	DB
40	Room 18 NW Wall	3.11	ug/L	DB
41	Room 17 NW Wall (water off)			
42	Room 16 NW Wall (water off)			
43	Bung. B1 - Interior - North Wall	4.58	ug/L	DB
44	Bung. B2 - Interior - North Wall	3.59	ug/L	DB
45	Bung. B3 - Interior - South Wall	6.41	ug/L	DB
46	Bung. B4 - Interior - North Wall	5.10	ug/L	DB
47	Bung. B5 - Interior - North Wall	4.01	ug/L	DB
48	Bung. B6 - Interior - South Wall	6.98	ug/L	DB
49	Bung. B7 - SE Wall	5.88	ug/L	DB
50	Bung. B8 - SE Wall (previously sampled)			
51	Bung. B9 SE Wall	5.92	ug/L	DB
52	Bung. B10 SE Wall	4.63	ug/L	DB

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

