



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 5/12/17


San Diego Unified School District
Euclid Elementary

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1168292	05/05/17	06:02 AM	SAMPLE 1	3710020-AHB-A	< 5	ug/L
W1168293	05/05/17	06:05 AM	SAMPLE 2	3710020-AHB-B	< 5	ug/L
W1168294	05/05/17	06:09 AM	SAMPLE 3	3710020-AHB-C	< 5	ug/L
W1168295	05/05/17	06:22 AM	SAMPLE 4	3710020-AHB-D	6.65	ug/L
W1168296	05/05/17	06:15 AM	SAMPLE 5	3710020-AHB-E	< 5	ug/L

Source **Source Description**

- SAMPLE 1 Building A; Lunch Patio on North end of campus near office; R-side bubbler on a 2-bubbler fountain
- SAMPLE 2 South end of Building A; Far R-side bubbler on a 3-bubbler fountain
- SAMPLE 3 North end Bldg. D; indoors first floor near restrooms; Lower R-side bubbler of 2 single fountains
- SAMPLE 4 Bldg. K; Outdoor bubbler facing west; Lower L bubbler of 2 single fountains
- SAMPLE 5 Child Development Center, w end of campus next to employee parking lot; Lower L bubbler of 2 single fountains

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Doug Campbell, Senior Chemist