

Water Quality Chemistry Services
 Lead School Testing
 Report Date: 28-Apr-2017

San Diego Unified School District
Gompers Preparatory Academy

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1166057	4/12/2017	5:40 AM	SAMPLE 1	3710020-ADG-A	< 5	µg/L
W1166058	4/12/2017	5:45 AM	SAMPLE 2	3710020-ADG-B	< 5	µg/L
W1166059	4/12/2017	5:48 AM	SAMPLE 3	3710020-ADG-C	< 5	µg/L
W1166060	4/12/2017	5:52 AM	SAMPLE 4	3710020-ADG-D	< 5	µg/L
W1166061	4/12/2017	5:56 AM	SAMPLE 5	3710020-ADG-E	< 5	µg/L

- | <u>Source</u> | <u>Source Description</u> |
|---------------|---|
| SAMPLE 1 | Auditorium, Exterior north wall, between girls/boys restrooms, dual fixture, left bubbler |
| SAMPLE 2 | Cafeteria, kitchen, food prep area, east wall, swing arm faucet |
| SAMPLE 3 | Locker room BLDG, north exterior wall at exercise room, dual fountain, right bubbler |
| SAMPLE 4 | Rooms 46-47A, west wall at 47A, dual fixture, right bubbler |
| SAMPLE 5 | Rooms 10-12, east wall across from 6/7th grade restroom, upper right bubbler |

DRL=State Mandated Detection Limit for Reporting (DLR)= 5 µg/L
 Action Level (AL) = 15 µg/L



Doug Campbell, Senior Chemist