



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 4/27/17

San Diego Unified School District
Iftin Charter

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1166072	04/12/17	05:57 AM	SAMPLE 1	3710020-ADH-A	< 5	ug/L
W1166073	04/12/17	06:02 AM	SAMPLE 2	3710020-ADH-B	< 5	ug/L
W1166074	04/12/17	06:11 AM	SAMPLE 3	3710020-ADH-C	< 5	ug/L
W1166075	04/12/17	06:04 AM	SAMPLE 4	3710020-ADH-D	< 5	ug/L
W1166076	04/12/17	06:14 AM	SAMPLE 5	3710020-ADH-E	< 5	ug/L

<u>Source</u>	<u>Source Description</u>
SAMPLE 1	BLDG 100, in kindergarten room1, bubbler at sink
SAMPLE 2	room 22, inside classroom, bubbler at sink
SAMPLE 3	BLDG 100, exterior facing coutyard, triple fountain, left bubbler
SAMPLE 4	BLDG 300, east facing exterior triple fountain, right bubbler
SAMPLE 5	BLDG 200, south facing exterior single & double fountain, left bubbler on double

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Doug Campbell, Senior Chemist