



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Lindbergh (West Campus)

Report Type: Progress Report

Date of Report: 02/19/19

Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
1 4 Clssrm 15-21 - Lindbergh Schweitzer_01-04 Building Exterior, Se Corner, Right Fixture, Right Bubbler	DWO-175-039	Drinking Fountain Bubbler	3.85		
2 4 Clssrm 15-21 - Lindbergh Schweitzer_01-04 Building Exterior, Se Corner, Left Fixture, Left Bubbler	DWO-175-040	Drinking Fountain Bubbler	1.85		
3 4 Clssrm 15-21 - Lindbergh Schweitzer_01-04 Building Exterior, Se Corner, Left Fixture, Right Bubbler	DWO-175-041	Drinking Fountain Bubbler	2.64		
4 4 Clssrm 15-21 - Lindbergh Schweitzer_01-04 Classroom - 21, East Wall	DWO-175-042	Drinking Fountain Bubbler	2.58		
5 4 Clssrm 15-21 - Lindbergh Schweitzer_01-04 Classroom - 20, West Wall	DWO-175-043	Drinking Fountain Bubbler	1.62		
6 4 Clssrm 15-21 - Lindbergh Schweitzer_01-04 Classroom - 19, East Wall	DWO-175-044	Drinking Fountain Bubbler	1.46		
7 1 Kinder Rms K01-K03 - Lindbergh Schweitzer_01-01 Classroom - K03, Bubbler At Island Sink	DWO-175-045	Drinking Fountain Bubbler	3.17		
8 1 Kinder Rms K01-K03 - Lindbergh Schweitzer_01-01 Classroom - K02, Bubbler At Island Sink	DWO-175-046	Drinking Fountain Bubbler	6.05		
9 1 Kinder Rms K01-K03 - Lindbergh Schweitzer_01-01 Building Exterior, South Wall, Left Bubbler	DWO-175-047	Drinking Fountain Bubbler	2.78		
10 1 Kinder Rms K01-K03 - Lindbergh Schweitzer_01-01 Building Exterior, South Wall, Right Bubbler	DWO-175-048	Drinking Fountain Bubbler	<5		
11 1 Kinder Rms K01-K03 - Lindbergh Schweitzer_01-01 Classroom - K01, Bubbler At Island Sink	DWO-175-049	Drinking Fountain Bubbler	3.07		
12 Portable B22 - Lindbergh Schweitzer Classroom - B22, South Wall	DWO-175-050	Drinking Fountain Bubbler	5.69		
13 Portable B23 - Lindbergh Schweitzer Classroom - B23, South Wall	DWO-175-051	Drinking Fountain Bubbler	6.94		
14 Portable B24 - Lindbergh Schweitzer Classroom - B24A, South Wall	DWO-175-052	Drinking Fountain Bubbler			
15 Portable B25 - Lindbergh Schweitzer Classroom - B25A, Speech Room Faucet	DWO-175-053	Faucet	0.76		
16 Portable B25 - Lindbergh Schweitzer Classroom - B25A, Speech Room Bubbler	DWO-175-054	Drinking Fountain Bubbler	5.97		



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Lindbergh (West Campus)

Report Type: Progress Report

Date of Report: 02/19/19

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
17	Portable B30 - Lindbergh Schweitzer Classroom - B30A, South Wall	DWO-175-055	Drinking Fountain Bubbler	5.04		
18	Portable B29 - Lindbergh Schweitzer Classroom - B29A, South Wall	DWO-175-056	Drinking Fountain Bubbler	1.61		
19	Portable B28 - Lindbergh Schweitzer Classroom - B28A, South Wall	DWO-175-057	Drinking Fountain Bubbler	2.06		
20	Portable B27 - Lindbergh Schweitzer Classroom - B27, South Wall	DWO-175-058	Drinking Fountain Bubbler	0.55		
21	Portable B26 - Lindbergh Schweitzer Classroom - B26, South Wall	DWO-175-059	Drinking Fountain Bubbler	0.71		
22	Portable Restrooms - Lindbergh Schweitzer Building Exterior, East Wall, Left Bubbler	DWO-175-060	Drinking Fountain Bubbler	0.42		
23	Portable Restrooms - Lindbergh Schweitzer Building Exterior, East Wall, Right Bubbler	DWO-175-061	Drinking Fountain Bubbler	0.44		
24	7 Library - Lindbergh Schweitzer_02-07 Building Exterior, East Wall, Left Bubbler	DWO-175-062	Drinking Fountain Bubbler	0.34		
25	7 Library - Lindbergh Schweitzer_02-07 Building Exterior, East Wall, Middle Bubbler	DWO-175-063	Drinking Fountain Bubbler	0.22		
26	7 Library - Lindbergh Schweitzer_02-07 Building Exterior, East Wall, Right Bubbler	DWO-175-064	Drinking Fountain Bubbler	0.18		
27	Portable B31 - Lindbergh Schweitzer Classroom - B31, East Wall	DWO-175-065	Drinking Fountain Bubbler	ND		
28	2 Admin - Lindbergh Schweitzer_01-02 Nurse Office - HLC1, Nw Wall	DWO-175-066	Faucet	1.82		
29	3 Audit/Kitchen/MPR - Lindbergh Schweitzer_01-03 Counseling Center, South Wall	DWO-175-067	Faucet	4.63		
30	3 Audit/Kitchen/MPR - Lindbergh Schweitzer_01-03 Building Exterior, East Wall, Left Bubbler	DWO-175-068	Drinking Fountain Bubbler	1.46		
31	3 Audit/Kitchen/MPR - Lindbergh Schweitzer_01-03 Building Exterior, East Wall, Right Bubbler	DWO-175-069	Drinking Fountain Bubbler	<5		
32	3 Audit/Kitchen/MPR - Lindbergh Schweitzer_01-03 Food Services/Kitchen - FSK1, West Wall Prep Sink	DWO-175-070	Spray Faucet	<5		



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Lindbergh (West Campus)

Report Type: Progress Report

Date of Report: 02/19/19

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
33	6 Clssrm 4-9 - Lindbergh Schweitzer_01-06 Classroom - 04, West Wall	DWO-175-071	Drinking Fountain Bubbler	2.21		
34	6 Clssrm 4-9 - Lindbergh Schweitzer_01-06 Classroom - 05, East Wall	DWO-175-072	Drinking Fountain Bubbler	3.62		
35	6 Clssrm 4-9 - Lindbergh Schweitzer_01-06 Classroom - 06, West Wall	DWO-175-073	Drinking Fountain Bubbler	1.70		
36	6 Clssrm 4-9 - Lindbergh Schweitzer_01-06 Classroom - 09, West Wall	DWO-175-074	Drinking Fountain Bubbler	3.48		
37	6 Clssrm 4-9 - Lindbergh Schweitzer_01-06 Classroom - 08, East Wall	DWO-175-075	Drinking Fountain Bubbler	10.40		
38	6 Clssrm 4-9 - Lindbergh Schweitzer_01-06 Classroom - 07, West Wall Faucet	DWO-175-076	Faucet	1.60		
39	6 Clssrm 4-9 - Lindbergh Schweitzer_01-06 Classroom - 07, West Wall Bubbler	DWO-175-077	Drinking Fountain Bubbler	1.45		
40	6 Clssrm 4-9 - Lindbergh Schweitzer_01-06 Building Exterior, West Wall, Left Bubbler	DWO-175-078	Drinking Fountain Bubbler	2.65		
41	6 Clssrm 4-9 - Lindbergh Schweitzer_01-06 Building Exterior, West Wall, Middle Bubbler	DWO-175-079	Drinking Fountain Bubbler	<5		
42	6 Clssrm 4-9 - Lindbergh Schweitzer_01-06 Building Exterior, West Wall, Right Bubbler	DWO-175-080	Drinking Fountain Bubbler	1.23		
43	5 Clssrm 10-14/Supply - Lindbergh Schweitzer_01-05 Classroom - 10, East Wall Faucet	DWO-175-081	Faucet	1.46		
44	5 Clssrm 10-14/Supply - Lindbergh Schweitzer_01-05 Classroom - 10, East Wall Bubbler	DWO-175-082	Drinking Fountain Bubbler	1.74		
45	5 Clssrm 10-14/Supply - Lindbergh Schweitzer_01-05 Classroom - 11, West Wall	DWO-175-083	Drinking Fountain Bubbler	2.22		
46	5 Clssrm 10-14/Supply - Lindbergh Schweitzer_01-05 Building Exterior, North Wall, Left Fixture, Left Bubbler	DWO-175-084	Drinking Fountain Bubbler	1.70		
47	5 Clssrm 10-14/Supply - Lindbergh Schweitzer_01-05 Building Exterior, North Wall, Left Fixture, Right Bubbler	DWO-175-085	Drinking Fountain Bubbler	0.57		
48	5 Clssrm 10-14/Supply - Lindbergh Schweitzer_01-05 Building Exterior, North Wall, Right Fixture, Left Bubbler	DWO-175-086	Drinking Fountain Bubbler	0.66		



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Lindbergh (West Campus)

Report Type: Progress Report

Date of Report: 02/19/19

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
49	5 Clsrm 10-14/Supply - Lindbergh Schweitzer_01-05 Building Exterior, North Wall, Right Fixture, Right Bubbler	DWO-175-087	Drinking Fountain Bubbler	0.38		
50	5 Clsrm 10-14/Supply - Lindbergh Schweitzer_01-05 Classroom - 14, North Wall Right Sink	DWO-175-088	Drinking Fountain Bubbler	0.85		
51	5 Clsrm 10-14/Supply - Lindbergh Schweitzer_01-05 Classroom - 14, North Wall Right Sink	DWO-175-089	Faucet	2.58		
52	5 Clsrm 10-14/Supply - Lindbergh Schweitzer_01-05 Classroom - 13, West Wall	DWO-175-090	Drinking Fountain Bubbler	1.29		
53	5 Clsrm 10-14/Supply - Lindbergh Schweitzer_01-05 Classroom - 12, East Wall	DWO-175-091	Drinking Fountain Bubbler	1.48		
54	4 Clsrm 15-21 - Lindbergh Schweitzer_01-04 Classroom - 15, East Wall	DWO-175-092	Drinking Fountain Bubbler	1.83		
55	4 Clsrm 15-21 - Lindbergh Schweitzer_01-04 Classroom - 16, West Wall	DWO-175-093	Drinking Fountain Bubbler	3.24		
56	4 Clsrm 15-21 - Lindbergh Schweitzer_01-04 Classroom - 17, East Wall	DWO-175-094	Drinking Fountain Bubbler	2.28		
57	4 Clsrm 15-21 - Lindbergh Schweitzer_01-04 Classroom - 18, West Wall	DWO-175-095	Drinking Fountain Bubbler	2.52		
58	4 Clsrm 15-21 - Lindbergh Schweitzer_01-04 Building Exterior, Se Corner, Right Fixture, Left Bubbler	DWO-175-096	Drinking Fountain Bubbler	1.84		
59	Portable B32 - Lindbergh Schweitzer Classroom - B32, East Wall	DWO-175-097	Drinking Fountain Bubbler	ND		
60	Portable B33 - Lindbergh Schweitzer Classroom - B33, West Wall	DWO-175-098	Drinking Fountain Bubbler	ND		
61	Portable B34 - Lindbergh Schweitzer Classroom - B34A, East Wall	DWO-175-099	Drinking Fountain Bubbler	0.47		
62	Portable B34 - Lindbergh Schweitzer Classroom - B34B, West Wall	DWO-175-100	Drinking Fountain Bubbler	0.60		
63	Portable B35 - Lindbergh Schweitzer Classroom - B35A, East Wall	DWO-175-101	Drinking Fountain Bubbler	0.38		



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Lindbergh (West Campus)

Report Type: Progress Report

Date of Report: 02/19/19

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
64	Portable B35 - Lindbergh Schweitzer Classroom - B35B, West Wall	DWO-175-102	Drinking Fountain Bubbler	0.43		
65	Portable B36 - Lindbergh Schweitzer Classroom - B36, Kitchen Sink Island	DWO-175-103	Faucet	0.37		
66	Portable B38 - Lindbergh Schweitzer Classroom - B38B, East Wall	DWO-175-104	Faucet	0.33		
67	Portable B38 - Lindbergh Schweitzer Classroom - B38B, East Wall	DWO-175-105	Drinking Fountain Bubbler	0.36		
68	Portable B49 - Lindbergh Schweitzer Classroom - B49, South Wall	DWO-175-106	Drinking Fountain Bubbler	1.46		
69	Portable B48 - Lindbergh Schweitzer Classroom - B48, South Wall	DWO-175-107	Drinking Fountain Bubbler	0.50		
70	Portable B47 - Lindbergh Schweitzer Classroom - B47, South Wall	DWO-175-108	Drinking Fountain Bubbler	0.46		
71	Portable B46 - Lindbergh Schweitzer Classroom - B46, South Wall	DWO-175-109	Drinking Fountain Bubbler	41.00		

*Action levels and color indication

Federal action level is above 15ppb (parts per billion). SDUSD uses an action level that is stricter and includes anything above 5 PPB. Items indicated in green are below District action level. Items indicated in yellow are above District action level. Items indicated in red are above both District and Federal action levels. Green indicates no action needed. Red/Yellow indicates action needed.

**Clearance actions

INIT=Initial result cleared no action needed. FLTR=Filter has been installed. PLMB=Plumbing work performed. RRC=Repeat and repeat-confirmation testing has been performed and both samples yielded results below District action level. RMOV=The drinking water outlet has been removed from service.