



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 5/26/17

San Diego Unified School District
Spreckels Elementary

| Sample ID | Sample Date | Sample Time | Source | External ID | Lead | Units |
|-----------|-------------|-------------|----------|---------------|------|-------|
| W1170184 | 05/18/17 | 05:57 AM | SAMPLE 1 | 3710020-BFI-A | < 5 | ug/L |
| W1170185 | 05/18/17 | 06:02 AM | SAMPLE 2 | 3710020-BFI-B | < 5 | ug/L |
| W1170186 | 05/18/17 | 06:08 AM | SAMPLE 3 | 3710020-BFI-C | < 5 | ug/L |
| W1170187 | 05/18/17 | 06:12 AM | SAMPLE 4 | 3710020-BFI-D | < 5 | ug/L |
| W1170188 | 05/18/17 | 06:16 AM | SAMPLE 5 | 3710020-BFI-E | < 5 | ug/L |

Source **Source Description**

- SAMPLE 1 Auditorium/Library Building, South facing wall outside of building near RRs, two single bubbler fountains, upper right fountain
- SAMPLE 2 Cafeteria/Kitchen Building, Inside kitchen on North side of building, faucet above right sink compartment next to spray nozzle
- SAMPLE 3 Red Door Building, outside North side of building, two single bubbler fountains, lower left fountain
- SAMPLE 4 Yellow Door Building, outside West side of building, two single bubbler fountains, upper right fountain
- SAMPLE 5 Green Door Building, outside West side of building, triple bubbler fountain, middle bubbler

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Doug Campbell, Senior Chemist