



Environmental Monitoring and Technical Services  
2392 Kincaid Road MS 45A, San Diego, CA 92101  
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services  
Lead School Testing  
Report Date: 5/4/17

San Diego Unified School District  
**Wangenheim Middle**

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1168551	04/26/17	06:24 AM	SAMPLE 1	3710020-BBI-A	< 5	ug/L
W1168552	04/26/17	06:20 AM	SAMPLE 2	3710020-BBI-B	< 5	ug/L
W1168553	04/26/17	06:12 AM	SAMPLE 3	3710020-BBI-C	< 5	ug/L
W1168554	04/26/17	06:14 AM	SAMPLE 4	3710020-BBI-D	< 5	ug/L
W1168555	04/26/17	06:08 AM	SAMPLE 5	3710020-BBI-E	< 5	ug/L

**Source**      **Source Description**

- SAMPLE 1      Bungalow Restrooms, Outside Between restrooms near room #23 and dirt field, dual bubbler fountain to the left of triple fountain, left bubbler on dual fountain
- SAMPLE 2      Outside West end of P E building Boys Gym, dual bubbler drinking fountain, right bubbler
- SAMPLE 3      Outside East side Girls Gym, triple bubbler fountain, right bubbler
- SAMPLE 4      West end of handball courts, dual bubbler fountain, left bubbler
- SAMPLE 5      500 bldg. Media Center, Outside South end between 507 & Girls RR, dual bubbler fountain, left bubbler

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L  
Action Level (AL) = 15 ug/L

  
Tom Burger, Associate Chemist