

Water Quality Chemistry Services
 Lead School Testing
 Report Date: 28-Apr-2017

San Diego Unified School District
Washington Elementary

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1168032	4/21/2017	6:05 AM	SAMPLE 1	3710020-AIB-A	< 5	µg/L
W1168033	4/21/2017	6:08 AM	SAMPLE 2	3710020-AIB-B	< 5	µg/L
W1168034	4/21/2017	6:11 AM	SAMPLE 3	3710020-AIB-C	< 5	µg/L
W1168035	4/21/2017	6:18 AM	SAMPLE 4	3710020-AIB-D	< 5	µg/L
W1168036	4/21/2017	6:23 AM	SAMPLE 5	3710020-AIB-E	< 5	µg/L

Source	Source Description
SAMPLE 1	West wing, 1st floor, near room 4, across from RR, triple fountain, left bubbler
SAMPLE 2	Multi purp bldg, exterior north wall, triple fountain, center bubbler.
SAMPLE 3	West wing, 1st floor, across from custodial supply and RM 17, upper right bubbler
SAMPLE 4	Kindergarten BLDG, exterior south wall, next to K-1, triple fountain, center bubbler
SAMPLE 5	CDC Classroom P-2, east wall, bubbler at sink

DRL=State Mandated Detection Limit for Reporting (DLR)= 5 µg/L
 Action Level (AL) = 15 µg/L



Doug Campbell, Senior Chemist